

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Chiping New Decor Building Material Co., Ltd.

Chiping Industrial Town, Liaocheng City, Shandong, China

For the following product(s):

Vinyl Flooring:

Luxury Vinyl Tile Flooring (Maximum thickness: 6.7mm)

Rigid Vinyl Plank Flooring (Maximum thickness: 7.5mm)

Stone Plastic Composite Flooring (Maximum thickness: 7.5mm)

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m^3 (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-06374

Valid from: August 27, 2024 to August 31, 2026

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



CERTIFIED BY
SCS Global Services



A handwritten signature in black ink, reading "Stanley Mathuram".

Stanley Mathuram, PE, Vice President

SCS Global Services

2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA